

Analysis of Power Transmission Line Uncertainties: Status Review

Tlotlollo S Hlalele^{1*} and Shengzhi Du²

¹University of South Africa, Cnr. Christiaan De Wet and Pioneer Avenue, Florida P.O. Box 392, UNISA 0003 RSA, South Africa

²Department of mechanical engineering at Tshwane University of Technology, Pretoria RSA, South Africa

Abstract

Uncertainties of environmental and physical parameters of outdoor power transmission lines are rarely known, though they are very critical in planning, operation and line uncertainty modeling for power utilities. Several approaches have been previously used to predict such parameters in wide transmission corridors. Transmission line uncertainty modeling can be challenging since it is based on the assumption of the unknown limits. This paper characterizes and evaluates these approaches. After comparative study, the interval mathematical approach is shown to be more versatile than the rest of the techniques because of the ability to stretch the unknown variable while bounded.

Keywords: Transmission line parameter estimation; Transmission line modeling; Power transmission

Introduction

Power transmission lines are very important in electricity power delivery because power stations are normally located at distance. Process and balance must be constantly maintained to match the power supply and demand. Climatic changes cause uncertainties, for instance stretch from wind force and temperature induced stress in our existing electrical transmission line performance as well as future designs. These uncertainties increase when longer time frames are considered. The electric current flowing in the lines should be correctly measured to avoid overloads, phase unbalance and fluctuation. Uncertainties concerned can be traced from line position which is depended on load changes, topology changes and changes in network parameters. Modeling uncertainties is based on two generic approaches which are probabilistic and unknown bounded. The first is where probability distributions for the uncertainties are assumed, and the second is where upper and lower limits on the uncertainties are assumed without probability distribution on the conductor [1].

Some uncertainties have impact on system reliability and power quality of service, which may be a losing of customers, for instance power quality sensitive customers. There can also be a swinging of the suspension points longitudinally to the power line which is likely caused by the variation in tension. For example, conductors between two transmission towers often suffer sagging and galloping phenomenon, which then may result in voltage sag. According to IEEE Standard 1159-1995 Recommended Practice for Monitoring Electric Power Quality, the voltage sag is a decrease in RMS at the power frequency for durations from 0.5 cycles to 1 minute, reported as the remaining voltage [2]. This standard only considers the voltage and current excludes the conductor capacitance and slag, which could result in increasing of line stress and even total failure.

Conductor Catenary Approach

The effect of wind force causes a line conductor to engorget and to some extent vibrate. If the conductor is damaged or the initial sag is incorrect, the line clearance may be violated and the conductor may experience a serious fatigue and break [3,4]. When uncertainty is analyzed, vibration of transmission line needs to be considered as well. When differential equations are employed to view the conductor line motion, the following assumptions are made:

Let $u(x, t) = \varphi(x) \cdot \gamma(t)$ and $\partial(x) = \mathcal{O}e^{xz}$ then following the motion equation;

$$E_r J_r \frac{\partial^4 u}{\partial x^4} - S \frac{\partial^2 u}{\partial x^2} = -m \frac{\partial^2 u}{\partial t^2} \quad (1)$$

$$\frac{1}{m\varphi(x)} \left[E_r J_r \frac{d^4 \varphi(x)}{dx^4} - S \frac{d^2 \varphi(x)}{dx^2} \right] = -\frac{1}{\gamma(t)} \cdot \frac{d^2 \gamma(t)}{dt^2} \quad (2)$$

$$E_r J_r \frac{d^4 \varphi(x)}{dx^4} - S \frac{d^2 \varphi(x)}{dx^2} = v^2 m \varphi(x) \quad (3)$$

$$\frac{d^2 \gamma(t)}{dt^2} = -v^2 \gamma(t) \quad (4)$$

$$\gamma(t) = \gamma_0 \sin(vt + \alpha) \quad (5)$$

Assuming that $\frac{d^2 \varphi(x)}{dx^2} = 0$ when $x = 0$ and $l = x$ then one gets a partial resonance frequency. Where the resonance frequency f_r^2 relates to the vibration modes causing uncertainties and expressed as;

$$f_r^2 = (\Pi r / l)^2 S / m [1 + (\Pi r / l)^2 \cdot (E_r J_r) / S] \quad (6)$$

This equation can be used to calculate bending stiffness of the transmission line. A value of this frequency could then be useful in line sag estimation. The future expansion of the transmission networks will also require analysis on bending limitations of the line. This can be done by looking at the lowest point of the conductor.

The estimated low point $y(x)$, of the conductor defined as catenary curve (Figure 1).

Height of the conductor above this low point is then given by;

$$y(x) = \frac{H}{w} \cosh \left(\left(\frac{w}{H} x \right) - 1 \right) = \frac{w(x^2)}{2H} \quad (7)$$

*Corresponding author: Hlalele TS, University of South Africa, Cnr. Christiaan De Wet & Pioneer Avenue, Florida P.O. Box 392, UNISA 0003 RSA, South Africa, Tel: +27-11-471-2099; E-mail: hlalets@unisa.ac.za

Received August 18, 2016; Accepted August 25, 2016; Published September 01, 2016

Citation: Hlalele TS, Du S (2016) Analysis of Power Transmission Line Uncertainties: Status Review. J Electr Electron Syst 5: 194. doi: 10.4172/2332-0796.1000194

Copyright: © 2016 Hlalele TS, et al. This is an open-access article distributed under the terms of the Creative Commons Attribution License, which permits unrestricted use, distribution, and reproduction in any medium, provided the original author and source are credited.




Figure 1: The catenary curve for level span.

For a level span, the low point is in the center, and the line sag, D , is found by

$$D = H / w(\cosh(ws / 2H) - 1) = (w(S^2)) / 8H \quad (8)$$

The end of the level span, conductor tension T , is equal to the horizontal component plus the conductor weight per unit length, W , multiplied by the sag, D as shown in equation (9).

$$T = H + wD \quad (9)$$

Considering the conductor length from the low point of the catenary from either direction of the sag on the catenary curve can be obtained as follows:

$$L(x) = \left(\frac{H}{w} \text{SINH} \left(\frac{Sw}{2H} \right) \right) = S \left(1 + \frac{x^2(w)^2}{6H^2} \right) \quad (10)$$

For a level span, the conductor length corresponding to $x=S/2$ is the half of the total conductor length and the total length, L , is [4]

$$L = \left(\frac{2H}{w} \right) \text{SINH} \left(\frac{Sw}{2H} \right) = S \left(1 + \frac{x^2(w)^2}{24H^2} \right) \quad (11)$$

Substituting parabolic equation of the sag one gets

$$L = S + \frac{8D^2}{3S} \quad (12)$$

Conductor slack is the difference between the conductor length, L , and the span length, S . The parabolic equations for slack may be found by combining the preceding parabolic equations for conductor length, L and sag, D [4].

$$L - S = S^3 \left(\frac{w^2}{24H^2} \right) = D^2 \left(\frac{8}{3S} \right) \quad (13)$$

A conductor slack in a span can contribute to the changes in conductor sag, such that:

$$D = \sqrt{\frac{3S(L-S)}{8}} \quad (14)$$

For inclined spans, they may be analyzed using essentially the same equations that are used for equally levelled spans. The catenary equation for the conductor height above the low point in the span is the same. For the span, we consider two separate sections, on to the right of the low point and the other to the left of the low point. The shape of the catenary relative to the low point is unaffected by the difference in suspension point elevation. In each direction from the low point, the conductor elevation relative to the low point is [4,5].

$$y(x) = \frac{H}{w} \cosh \left(\left(\frac{w}{H} x \right) - 1 \right) = \frac{wx^2}{2H} \quad (15)$$

The horizontal distance X_L from the left support point to the low point in the catenary is [4]

$$x_L = \frac{S}{2} \left(1 + \frac{h}{4D} \right) \quad (16)$$

The horizontal distance, X_R , from the right support point to the low point of the catenary is [4]:

$$x_R = \frac{S}{2} \left(1 - \frac{h}{4D} \right) \quad (17)$$

From the inclined catenary span S_1 is the straight-line distance between supporting points, S is the horizontal distance between supportsh is the vertical distance between support points, D is the sag measured vertically from a line through the points of conductor support to a line tangent to the conductor [4].

The midpoint sag D is approximately equal to the sag in a horizontal span equal to the length to the inclined span. Knowing the horizontal distance from the low point to the support point in each direction, the preceding equations for $y(x)$, L , D , and T can be applied to each side of the inclined span. The total length in the inclined span is equal to the sum of the lengths in X_R and X_L sub-span sections [4,6,7].

$$L = S + (X_R^3 + X_L^3) \left(\frac{w^2}{6H^2} \right) \quad (18)$$

View of a position vector for conductor

When we review the position of a stretched conductor as presented by authors [8,9], in the form of a position vector $P(l,t) = (X(l,t), Y(l,t))$ with corresponding tension vector

$$T(l,t) = T(l,t) (\cos\psi, \sin\psi), \quad (19)$$

where ψ is the positively oriented angle between the cable tangent and the horizontal.

Tension vector is tangent to the cable or the conductor because of the assumed negligible bending stiffness. Although this might not always be the case, we agree with the authors [2,4,9], that the conductor element stretched under tension is represented as $(dx^2 dy^2)^{1/2}$ (Figure 2).

When a small cable element is considered, dl . Due to gravity, cable tension, and inertial forces, this element is stretched however the mass remain the same. A conductor element is elongated in proportion to tension, according to Hooke's law, such that [8]:

$$\left(dX^2 + dY^2 \right)^{1/2} = \left(1 + \frac{T}{EA} \right) dl.A \quad (20)$$

According to a Newton's law, the internal tension and the external gravity forces are in equilibrium with the inertial forces, such that;

$$dT = \left(ge_y + \frac{d^2y}{dx^2} \right) m dl$$

$$\frac{\partial X}{\partial l} = \left(1 + \frac{T}{EA} \right) \cos\psi, \frac{\partial Y}{\partial l} = \left(1 + \frac{T}{EA} \right) \sin\psi, \quad (21)$$

The equation result in the limit $dl \rightarrow 0$ are given in [8]

$$\frac{\partial}{\partial l} \left(\frac{T}{1 + \frac{T}{EA}} \frac{\partial X}{\partial l} \right) = m \frac{\partial^2 X}{\partial t^2}, \quad (22)$$




Figure 2: Conductor under tension stretch.




Figure 3: Boundary conditions.

$$\frac{\partial}{\partial l} \left(\frac{T}{1 + \frac{T}{EA}} \frac{\partial Y}{\partial l} \right) = m \frac{\partial^2 Y}{\partial l^2} + mg, \quad (23)$$

$$\left(\frac{\partial X}{\partial l} \right)^2 + \left(\frac{\partial Y}{\partial l} \right)^2 = \left(1 + \frac{T}{EA} \right)^2. \quad (24)$$

For the boundary and coupling conditions in Figure 3,

Where $L=0$ and $L=NL$. For a fixed support

$$X = 0, Y = 0, (l = 0),$$

At suspension string [8]:

$$[X]_{l=nL-}^{l=nL+} = 0,$$

$$(X - nS)^2 + (Y - a)^2 = a^2, \quad (25)$$

$$[T \cos(\phi - \psi)]_{l=nL-}^{l=nL+} = 0. \quad (26)$$

Where ϕ is the angle of the suspension string.

This approach helps to understand the problem of sag more clearly and the behavior of the transmission line under galloping conditions. Hence it helps to reduce various problem parameters in to a single clear problem.

Dynamic simulation

Computer program application to model the time varying behaviour of a system or in particular a transmission line, when it is described by ordinary differential equations or partial differential equations is known to be dynamic simulation. When bounding uncertainty is considered in dynamic simulation, correct parameter values is unlikely known. It is common for the range of a parameter value to be considered. A statistical distribution could then be estimated or predicted.

For instance we can assume that parameters are uniformly distributed between some lower and upper bounds. Alternatively, there may be sufficient data to assume a normal distribution with some mean and variance [10-13]. Simulation of large data sets is not accurate to predict uncertainties, since parameters are mostly based on assumptions.

The well know Monte-Carlo and Simulink technique is mostly used to quantify the uncertainty in a trajectory [14-16]. When other transmission equipment is taken into consideration, such as transformers, the load time constant TP and the transformer tapping delay T_{tap} should be carefully looked after. This method results in errors occur due to uncertainties.

Interval mathematical approach

Interval mathematics use interval numbers instead of ordinary single point numbers. This interval number is defined as an ordered pair of real numbers representing the lower and upper bounds of the parameter range [17-19]. If the interval numbers are given as $[a, b]$ and $[c, d]$ then the following laws can be adapted for calculation;

$$[a, b] + [c, d] = [a + b, b + d] \quad (27)$$

$$[a, b] - [c, d] = [a - d, b - c] \quad (28)$$

$$[a, b] * [c, d] = [\min(ac, ad, bc, bd), \max(ac, ad, bc, bd)] \quad (29)$$

$$[a, b] \div [c, d] = [a, b] * \left[\frac{1}{d}, \frac{1}{c} \right], \text{ where } 0 \notin [c, d] \quad (30)$$

Traditionally power transmission is performed using two or more conductors for single-phase or multiphase systems. A problem appears in three-phase lines as a result of distribution of the phases over the length of the line [17].

Positions of phase a, b, and c lines change in a cycle that puts each phase in three possible positions over the line span. This cycle is to ensure that each phase experiences an equivalent amount of flux linkage. Thus, the average inductance of each of the phases will be equal.

If all three conductors have the same radius r , they will have the same inductance L :

$$L = 2 \times 10^{-7} \ln \left[\frac{(D_{12} D_{23} D_{31})}{(3r')^3} \right] \quad (H / m) \quad (31)$$

Where D_{12}, D_{23}, D_{31} , and r' are defined as follows:

D_{12} is the distance in meters between phase conductors 1 and 2,

D_{23} is the distance in meters between phase conductors 2 and 3,

and D_{13} is the distance in meters between phase conductors 1 and 3.

$r'_{12} = re - 1/4$ which is the radius in meters the accounts for internal inductance [18].

Although the calculations of uncertainties can be performed with interval mathematics, the variation of conductor length during temperature changes and loads from rain, snow or ice needs to be taken into consideration; however it is hard to be known especially in the real time base.

Synchronized-phasor measurements

The network, Figure 4 represents line parameter estimation for sending and receiving end voltages and currents.

Where,




Figure 4: Line parameter estimation for sending and receiving end voltages and currents.

$$V_s = (1 + ZY)V_r + ZI_r \quad (32)$$

$$I_s = (2Y + ZY^2)V_r + (1 + ZY)I_r \quad (33)$$

Where V_s and V_r are the sending and receiving end voltages respectively. I_s and I_r are sending and receiving end currents. Z and Y are impedance and admittance of the network.

Therefore,

$$Z = \frac{V_s^2 - V_r^2}{I_s V_r + V_s I_r} \quad (34)$$

$$Y = \frac{I_s - I_r}{V_s - V_r} \quad (35)$$

Synchronization angle δ is used to synchronize the voltage phasors at both the terminals. Using the synchronization angle δ , the phasors at the bus i with respect to global positioning system (GPS) reference can be defined as

$$V_s = V_s \angle \delta = V_s (\cos \delta + j \sin \delta) \quad (36)$$

$$V_r = V_r \angle (\delta - \phi_s) = V_r (\cos(\delta - \phi_s) + j \sin(\delta - \phi_s)) \quad (37)$$

Where ϕ_s is the power factor angle. Using a specified maximum measurement uncertainty, bounds of the line parameters can be calculated [19,20]. Using the values of the maximum measurement uncertainties, the standard uncertainties in the measurements can be calculated as;

$$u(q(k)) = \frac{\sqrt{q(k)}}{\sqrt{3}} \quad (38)$$

Where, $u(q(k))$ is the maximum specified uncertainty specified by the manufacturer in the measurement of the parameter $q(k)$.

The standard uncertainties in the power factor angle ϕ_s and the synchronization angle δ can be calculated: [20,21].

$$u(\phi_s) = \sqrt{\sum_{k=1}^3 \left[\frac{\partial \phi_s}{\partial p(k)} \right]^2 [u(p(k))]^2} \quad (39)$$

$$u(\delta) = \sqrt{\sum_{k=1}^7 \left[\frac{\partial \delta}{\partial Q(k)} \right]^2 [u(q(k))]^2} \quad (40)$$

Where ϕ_s is the power factor which is determined using the reactive power Q_s . $P(k)$ is the phase current. The lagging and leading power factor can be differentiated by the sign of Q_s . The power factor is lagging if the sign of Q_s is -ve and it is leading if Q_s is +ve.

The standard uncertainty in the power factor angle ϕ_s and the synchronization angle δ can be calculated by [22] classical uncertainty propagation theory.

Global positioning system

This is piloted based on a constellation of 24 satellites, which uses the Navigation satellite Timing and Ranging (NAVSTAR) developed, launched, and maintained by the United States government [23-29]. This method relies on accurate time-pulsed radio signals in the order of nanoseconds from high altitude Earth orbiting satellites of about 11 000 nautical miles, with the satellites acting as precise reference points. These signals are transmitted on two carrier frequencies known as the L1 and L2 frequencies. The L1 carrier is 1.5754GHz and carries a pseudo-random code (PRC) and the status message of the satellites.

There is a potential in this technology, although there are some errors contributing to estimates. The differential GPS is generally used in order to decrease the selective availability errors. The accuracy of the direct instrumentation of overhead power line conductor sag measurement is about 19.6 cm range and 70% of the time [30-35].

This technique is promising, however the challenge such as electromagnetic interference (EMI) from the phase conductors is questionable [36,37].

Detection via image processing

There are some optimized edge detectors in image processing, such as canny edge detectors and infinite symmetric exponential filter. These detectors follow different algorithms such as for canny edge detection, it is represented as follows [38,39]:

1. Read the image I .
2. Convolve a 1D Gaussian mask with I .
3. Create a 1D mask for the first derivative of the Gaussian in the x and y directions.
4. Convolve I with G along the rows to obtain I_x , and down the columns to obtain I_y .
5. Convolve I_x with G_x to have I_x' , and I_y with G_y to have I_y' .
6. Find the magnitude of the result at each pixel

$$M(x, y) = \sqrt{I_x'(x, y)^2 + I_y'(x, y)^2} \quad (41)$$

The Infinite Symmetric Exponential Filter uses another optimization function to find the edge in an image this function can be written as [39]:

$$C_N^2 = \frac{4 \int_0^\infty f^2(x) dx \cdot \int_0^\infty f'^2(x) dx}{f^4(0)} \quad (42)$$

The function C_N is minimized with an optimal smoothing filter for an edge detector, which results in an infinite symmetric exponential filter, as follows [39]:

$$f(x) = \frac{P}{2} e^{-P|x|}, f(x, y) = a e^{-P(|x|+|y|)} \quad (43)$$

The filter in the infinite symmetric exponential filter edge detector is presented as one dimensional recursive filter. P is the probabilistic transition, x and y are horizontal and vertical derivatives. By presuming the 2D-filter function real continuous, it is given by [39];

$$f[i, j] = \frac{(1-b)b^{|i|+|j|}}{1+b} \quad (44)$$

In some instances, image processing techniques use automatic image analysis technique for extracting information from the line insulators. No uncertainty predictions can be evident with this technique.

Conclusion

The current power system is ideally exposed to different environmental factors which result in uncertainty problems. The methods discussed in this paper mostly do the determination of line parameters by means of calculations. Even though calculations are somehow accurate, errors do occur in the life of existing lines due to unpredicted temperature boundaries, wind forces, load from snow or ice, etc. The challenge still remains to develop a technique for real-time uncertainty modeling tool, which can be used to detect live transmission line conductor directly, for further accurate measurements and studies. GPS could be more valuable in future if the EMI challenge is conquered. The advancement in research for other technologies based on electro-magnetic field theory is needed to address these limitations. Interval mathematics is more versatile compared to other methods such as synch phasor technique. The unknown variable can be stretched while bounded and it has shown to be faster than Monte Carlo methods in solving alternating current network problems.

References

- Cataliotti A, Di Cara D, Emanuel AE, Nuccio S (2008) Characterization of current transformers in the presence of harmonic distortion. Instrumentation and Measurement Technology Conference Proceedings, IEEE Victoria, Vancouver Island, Canada.
- IEEE Recommended Practice for Monitoring Electric Power Quality (2009).
- Hall G (2008) Maxwell's electromagnetic theory and special relativity. Phil Trans R Soc A.
- Douglass DA, Trash R (2013) Sag and Tension of conductor.
- Jiang JA, Lin YH, Yang JZ, Too TM, Liu CW (2000) An adaptive PMU based fault detection/location technique for transmission lines, PMU implementation and performance evaluation. IEEE Trans. Power Del 15: 1136-1146.
- Moore R (1996) Interval Analysis. Prentice-Hall, Englewood Cliffs, NJ.
- Abouelsaad M, Gawad NA, Bahy ME, Ata MAE, Shair IME (2006) Capacitor allocation and sizing in distribution feeders using interval mathematics. Power Systems Conference, MEPCON.
- Rienstra SW (1988) Nonlinear free vibration of coupled of overhead transmission lines.
- Saadat H (2004) Power System Analysis. (2nd edn) Boston: McGraw-Hill.
- Pawar D, Radhakrishna C, Jain HS, Ravichander S (2009) Non-iterative radial network power flow with parameter uncertainties: Interval mathematics. IEEE Region 10 Conference – TENCON.
- Burke W, Merrill H, Schweppe F, Lovell B, McCoy M (1998) Trade Off Methods In System Planning. IEEE Transactions on Power Systems 3: 1284-1290.
- Schweppe FC (1973) Uncertain Dynamic Systems. Prentice Hall.
- Aperjis D, White DC, Schweppe FC, Mettler M, Merrill HM (1982) Energy Strategy Planning for Electric Utilities, Part I, the SMARTED Methodology. IEEE Transactions on Power Apparatus and Systems 101: 340-346.
- Merrill HM, Schweppe F (1984) Strategic Planning for Electric Utilities: Problems and Analytic Methods 14: 72-83.
- Locci N, Muscas C, Sulis S (2006) Modeling ADC nonlinearity in Monte Carlo procedures for uncertainty estimation. IEEE Trans. Instrum. Meas 1671-1676.
- Indulkar CS, Ramalingam K (2008) Estimation of transmission line parameters from measurements. Int. J. Electr. Power Energy Syst 30: 337-342.
- Villiers W, Burger A, Cloete JH, Wedepohl LM (2008) Real-time sag monitoring system for high voltage transmission lines based on power-line carrier signal behaviour. IEEE Trans On power del.
- Shultz RD, Smith RA (1985) Introduction to Electric Power Engineering. Harper & Row, New York, NY.
- Jiang JA, Ya JZ, Lin YH, Liu CW, Ma JC (2000) An adaptive PMU based fault detection/location technique for transmission lines. I. Theory and algorithms. IEEE Trans. Power Del., vol. 15: 486-493.
- Kundur P (2008) Power System Stability and Control. New York, NY, USA: McGraw-Hill.
- Das B (2002) Radial distribution system power flow using interval arithmetic. Elect. Power Energy Syst 24: 827-836.
- ISO-IEC-OIML-BIPM: Guide to the Expression of Uncertainty in Measurement, JCGM/WG 1, 1992.
- Mensah-Bonsu C, Krekeler UF, Heydt GT, Hoverson Y, Schilleci V, et al. (2002) Application of the Global Positioning System to the Measurement of overhead Power Transmission Conductor Sag. IEEE Trans. Power Del 17: 273-278.
- Olsen RG, Edwards KS (2002) A new method for real-time monitoring of high voltage transmission line conductor sag. IEEE Trans. Power Del 17: 1142-1152.
- Fish L (2006) Low Cost Sensors for Real Time Monitoring of Overhead Transmission Lines. Washington, DC: Underground Systems Inc.
- Tension Monitor (2010).
- Sun X, Lui KS, Wong KKY, Lee WK, HouY, et al. (2011) Novel application of Magnetoresistive Sensors for High-Voltage Transmission-Line Monitoring. IEEE on Magnetics.
- Zhu X, Zhou J, Wang H, Fang L, Zhao M (2006) An Autonomous Obstacles Negotiating Inspection Robot for Extra-High Voltage Power Transmission lines. International Conference on Control, Automation, Robotics and Vision.
- Tunstal MJ, Masoud F, Kjell H, Dave H, Dave H, et al. (2007) State of the art of conductor galloping. Technical Brochure.
- Hlalele TS, Du S (2013) Application of a Radio Frequency Identification Technology on High voltage Transmission Line for conductor sag measurement. International Journal of Electrical, Computer, Energetic, Electronic and Communication Engineering
- Broadwater RP, Shaalan HE, Fabrycky WJ, Lee RE (1994) Decision evaluation with interval mathematics: a power distribution system case study. IEEE Trans. Power Delivery, vol. 9: 59-67.
- Ekstrom P, Eikos A (2005) Eikos Simulation Toolbox for Sensitivity Analysis. Facilia AB, The Norwegian Radiation Protection Authority and Posiva Oy.
- Alereld G, Mayer C (2000) Interval analysis theory and applications. Journal of Computational and Applied Mathematics 121: 421-464.
- Barboza LV, Dmuro GP, Reiser RHS (2004) Towards Interval Analysis of the Load Uncertainty in Power Electric Systems. International Conference on Probabilistic Methods Applied to Power Systems, Iowa State University, Ames, Iowa.
- Shaalan H (2012) Transmission line analysis using interval mathematics. North American Power Symposium (NAPS).
- Vaccaro A, Cañizares CA, Bhattacharya K (2009) A Range Arithmetic Based Optimization Model for Power Flow Analysis Under Interval Uncertainty Analysis by Interval Constraint Propagation. IEEE Trans. Power Systems 24: 28-39.
- Gu YH, Berlinj S (2013) Practical applications of automatic image analysis for overhead lines. Int. Conf. on Electricity distribution, Stockholm.
- Shaalan H (2000) Transmission line analysis using interval mathematics. Proceedings of 4th IASTED International Conference on Power & Energy Systems, Marbella, Spain.
- Martin AS (2016) Tosunoglu Image processing technique for machine vision. Univ. of Florida.